DIN CERTCO
Gesellschaft für Konformitätsbewertung mbH

CERTIFICATE

Certificate holder	**Centraltubi S.p.A.** **Via Foglia 11** **61020 Lunano PU** **ITALY**
Production facility	Lunano, ITALY
Product	Pipes made from Polyethylene for alternative installation techniques
Classification	EG 926.3, Outside diameter 250 mm up to 630 mm
Type, Model	CENTRALTUBI EUROPAS EVOLUTION
Remarks to the type	PAS 1075 Type 1 - TW Basis EN 12201-2
Testing basis	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)
Mark of conformity	DIN plus
Registration No.	P1R0450
Valid until	2026-02-28
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2021-02-12

Dipl.-Phys. Carlo Seiser
Head of Certification Body

GESELLSCHAFT FÜR KONFORMITÄTSBEWERTUNG MBH
DIN CERTCO

DIN

DIN CERTCO
Gesellschaft für Konformitätsbewertung mbH

ANNEX

Certificate	P1R0450 dated 2021-02-12
Technical Data	PAS 1075 Type 1 - TW Basis EN 12201-2 Outer diameter 250 mm up to 630 mm Maximum wall thickness 42,1 mm Material: PE 100-RC Type: see production facility related material list Colour: black with royal blue stripes Operating over pressure burstlining: see Certification Scheme Plastic piping systems (Pressure pipes and fittings)(2017-05) Annex 0 14
Testing laboratory/ Inspection body	Hessel Ingenieurtechnik GmbH Am Münsterwald 3 52159 Roetgen GERMANY
Test report(s)	R16 02 2915-A-ACT dated 2016-01-21 R20 03 3790-C_ACT dated 2020-03-19 R20 03 3900-C_ACT dated 2020-12-12 R20 03 3900-C_PLT+ dated 2020-12-12