

# CERTIFICATE

<b>Certificate holder</b>	<b>Centraltubi S.p.A.</b> <b>Via Foglia 11</b> <b>61020 Lunano PU</b> <b>ITALY</b>
<b>Production facility</b>	Lunano, ITALY
<b>Product</b>	Pipes made from Polyethylene for alternative installation techniques
<b>Classification</b>	EG 926.2, Outside Diameter 75 mm up to 225 mm
<b>Type, Model</b>	CENTRALTUBI EUROPAS EVOLUTION
<b>Remarks to the type</b>	PAS 1075 Type 2/2 - G Basis EN 1555-2
<b>Testing basis</b>	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)

**Mark of conformity**



**Registration No.** P1R0445

**Valid until** 2025-12-31

**Right of use** This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2021-02-05

*C. Seiser*  
Dipl.-Phys. Carlo Seiser  
Head of Certification Body



# ANNEX

<b>Certificate</b>	P1R0445 dated 2021-02-05
<b>Technical Data</b>	<p>PAS 1075 Typ 2/2 - G Basis EN 1555-2</p> <p>Outer diameter 75 mm up to 225 mm Minimum wall thickness 3,0 mm</p> <p>Material: PE 100-RC</p> <p>Type: see production facility related material list</p> <p>Colour inner layer: black Colour outer layer: orange yellow</p> <p>Operating over pressure burstlining: see Certification Scheme Plastic piping systems (Pressure pipes and fittings)(2017-05) Annex O 14</p>
<b>Testing laboratory/ Inspection body</b>	Hessel Ingenieurtechnik GmbH Am Münsterwald 3 52159 Roetgen GERMANY
<b>Test report(s)</b>	R20 03 3900-B_PLT+ dated 2020-12-12 R20 03 3900-B_ACT dated 2020-12-12 R20 03 3790-B_ACT dated 2020-03-19 R13 01 2303-A-FNCT-ACT dated 2013-05-02 R15 01 2539-B-(PLT) dated 2015-02-25