



Certificate of Compliance

This certificate is issued for the following:

Polyethylene Pipe for Underground Fire Protection Service

| Product Description | Nominal Pipe Size, in. | Pressure Rating, psi (bar) |
|---------------------|---|----------------------------|
| PE100 SDR11 Pipe | 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 630 | 200 (14) |
| PE100 SDR9 Pipe | 63, 75, 90, 110, 125 | 230 (16) |
| PE100 SDR9 Pipe | 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 630 | 260 (18) |

Prepared for:

Centraltubi S.p.A.
Via Foglia 11
61026 Lunano (PU)
Italy

FM Approvals Class: 1613 - February 2017

Approval Identification: PR453811

Approval Granted: March 3, 2020

To verify the product continues to be Approved please refer to www.approvalguide.com.

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "D.B. Fuller".

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group