

# CERTIFICATE

<b>Certificate holder</b>	<b>Centraltubi S.p.A.</b> <b>Via Foglia 11</b> <b>61020 Lunano PU</b> <b>ITALY</b>
<b>Production facility</b>	Lunano
<b>Product</b>	Pipes made from Polyethylene for alternative installation techniques
<b>Classification</b>	EG 926.4, Outside Diameter 710 mm
<b>Type, Model</b>	CENTRALTUBI EUROPAS EVOLUTION
<b>Remarks to the type</b>	PAS 1075 Type 2/2 - TW Basis EN 12201-2
<b>Testing basis</b>	PAS 1075:2009-04 Certification Scheme Plastic pipe system (pressure pipes and fittings (2015-03)

**Mark of conformity****Registration No.** P1R0449**Valid until** 2021-02-28**Right of use** This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.  
See annex for further information.

2016-02-10

Dipl.-Wi.-Ing. (FH) Sören Scholz  
Head of Certification Body

S. S 7



# ANNEX

Page 1 of 1

<b>Certificate</b>	P1R0449 dated 2016-02-10
<b>Technical Data</b>	Material: PE 100-RC Type: see production facility related material list Operating pressure Berstlining: max. 5 bar (SDR 11) Colour: black with royal blue outer layer
<b>Testing laboratory/ Inspection body</b>	Hessel Ingenieurtechnik GmbH Am Münsterwald 3 52159 Roetgen GERMANY
<b>Test report(s)</b>	R1602 2915-A_ACT dated 2016-01-21

